


Gulf Coast CHP Applications Center

New Orleans, Louisiana
July 28, 2005



U.S. Energy Flow Trends – 2000

Net Primary Resource Consumption 98.5 Quads



Source: Production and end-use data from Energy Information Administration, Annual Energy Review 2000


*Net fossil-fuel electrical imports

**Biomass/other includes wood and waste, geothermal, solar, and wind.

December 2001
Lawrence Livermore
National Laboratory

Waste is Costly!

Diagram 5. Electricity Flow, 2003
(Quadrillion Btu)



^a Blast furnace gas, propane gas, and other manufactured and waste gases derived from fossil fuels.

^b Batteries, chemicals, hydrogen, pitch, purchased steam, sulfur, and miscellaneous technologies.

^c Pumped storage facility production minus energy used for pumping.

^d Approximately two-thirds of all energy used to generate electricity. See note "Electrical System Energy Losses," at end of Section 2.

^e Data collection frame differences and nonsampling error.

^f Electric energy used in the operation of power plants, estimated as 5 percent of gross generation. See note "Electrical System Energy Losses," at end of Section 2.

^g Transmission and distribution losses (electricity losses that occur between the point of generation and delivery to the customer) are estimated as 9 percent of gross generation. See note "Electrical System Energy Losses," at end of Section 2.

^h Commercial retail sales plus approximately 95 percent of "Other" retail sales from Table 8.9.

ⁱ Approximately 5 percent of "Other" retail sales from Table 8.9.

^j Commercial and industrial facility use of onsite net electricity generation; and electricity sales among adjacent or co-located facilities for which revenue information is not available.


Note: Totals may not equal sum of components due to independent rounding.

Sources: Tables 2.1b-2.1e, 8.1, 8.4a, and A6 (column 4).

The Need For CHP in the USA




Stagnant Efficiency of U.S. Electric System



Source: EIA, Annual Energy Review 1996

CHP: the “Crown Jewel” of Distributed Generation



Why CHP? Why Not!




1. Improved fuel efficiency (fuel economy)
2. Improved power quality/reliability
3. Improved energy cost predictability
4. Reduced emissions per unit of useful output
5. Reduced grid congestion (deferred T&D investment)
6. No Ratepayer Investment Required (generation or T&D)
7. Reduced system vulnerability
8. Short lead-time, off-the-shelf, modular technology
9. Reduced land-use impacts
10. Eliminates line losses
11. Optimizes scarce natural gas resources
12. Creates new high-tech manufacturing sector of the economy
13. Supports competitive electric industry market structure

National CHP Strategy



- 92 GW of CHP by 2010
- Deploy CHP Applications Centers (RACs) to develop regional strategies:
 - Educate end-users and stakeholders about CHP
 - Provide technical assistance to adopters, developers, and regulators
 - Provide project specific support



Regional Application Centers

The regional application centers will promote combined heating and power (CHP) technology and practices, serve as a central repository and clearinghouse of CHP information, and identify and help implement regional CHP projects.




Gulf Coast Regional CHP Applications Center



- Established Jan 1, 2005
- Located at HARC in the Woodlands, Texas
- Serves Louisiana, Oklahoma, & Texas
- Website: www.gulfcoastchp.org

Roadmap Workshop held April 26-27, 2005

Progress – 81 GW in 2004




Source: EEA, Inc.

Industrials Represent Close to 90% of Existing CHP



- *Existing CHP Capacity (2004): 80,905 MW*




Source: EEA, Inc.

But Over 50% of the Installations are Commercial/Institutional




- Existing CHP Capacity (2004): 2,845 sites





Source: EEA, Inc.

The Gulf Coast Region Represents 29% of Existing CHP Capacity



U.S. = 80,905 MW
2,845 sites




Gulf Coast = 23,365 MW
213 sites

Source: EEA, Inc.

Industrials Represent 98% of Existing CHP in the Region



- *Existing CHP Capacity (2004): 23,365 MW*




Source: EEA, Inc.




Large Systems (>100 MW) Represent 83% of the Region's CHP Capacity

- *Existing CHP Capacity (2004): 23,366 MW*



Source: EEA, Inc.

The Potential for CHP at Industrial Facilities is over 11,000 MW



Source: EEA, Inc.

49% of the CHP Potential Is Below 5 MW in Size



	CHP Potential, MW			
	< 1MW	1-5 MW	5-20 MW	>20 MW
Commercial	3,738	2,619	1,831	544
Industrial	<u>1,099</u>	<u>2,184</u>	<u>3,158</u>	<u>4,631</u>
	4,837	4,803	4,989	5,175

Source: EEA, Inc.

Gulf Coast RAC Priority Areas



- Institutional Buildings
 - Hospitals, universities, prisons, government bldgs
 - Leverage CHP into Green Building protocols
 - Use thermal energy primarily for cooling (CCHP)
 - 1- 20 MW prime mover
- Medium Industrial
 - < 20 MW prime mover
- Large Industrial
 - Waste heat recovery
 - Boiler replacements and NOx compliance
 - Repowering existing CHP

The Domain


Austin, Texas



- Connected to Austin Energy's grid and to an existing District Cooling system
 - Provides 4.5 MW & 2500 tons of chilled water (44 F)
- Features:
 - Low emission gas turbine generator (Solar Turbines)
 - Two-stage indirect fired absorption chiller utilizing the turbine generator exhaust (Broad USA)
 - Packaged "skid mounted" by Turbine Air Systems
- Performance: Efficiency is 88.8% (LHV)




CHP System Elevation View



HEB Grocery Store San Antonio, Texas



- An existing 77,782 square foot supermarket.
 - Capstone micro-turbine (60kW)
 - Single effect Broad absorption chiller (18 tons)



HEB Grocery Store San Antonio, Texas



Goal

- reduce refrigeration costs

Method


- use the absorption chiller to provide sub-cooling to low and moderate temp refrigeration racks using thermal energy produced by the microturbine

Result

- for each ton of cooling supplied by the absorption chiller, compressor demand is reduced by 1 - 1.5 kW for medium temperature racks and 2 - 2.5 kW for low temperature racks.



Refrigerated Display Cases




One of Four Subcooling HXs added to Racks

Dell Children's Hospital Austin, Texas



- On-site energy is primary supply – the grid is back up
- Exceeds Texas Department of State Health Service's Life Safety power requirements
- Supports micro-grid
- Thermal to hospital and a new district cooling system
- Maximizes efficiency and environmental LEED credits with the goal of achieving the Platinum level
- Expected system heat rate near 5,000 Btu/kWh (beats best combined cycle power generation)



Get Involved!



- Participate in RAC activities:
 - Advisory Committee
 - CHP Summit Organizing Committee
 - Benefits & Barriers Study team
 - Institutional Buildings Study team
- Participate in non-RAC activities:
 - CHP “Initiative” – an ad-hoc, industry-led advocacy organization driving CHP issues in the region

For more information:



Daniel Bullock
Gulf Coast CHP Applications Center
(281) 364-6087

dbullock@gulfcoastchp.org

Thank You!