ADDENDUM NO. 1 TO BID DOCUMENTS

FOR

CIAP FRESHWATER BAYOU BANK STABILIZATION PROJECT STATE PROJECT NO. TV-11b(EB)

VERMILION PARISH, LOUISIANA





STATE OF LOUISIANA COASTAL PROTECTION AND RESTORATION AUTHORITY

AUGUST 8, 2013

S/A 8242-02

This addendum shall be considered part of the Plans, Specifications, and Contract Documents (except as noted otherwise) and is issued to change, amplify, or delete from or otherwise explain these documents where provisions of this addendum differ from those of the original documents. This addendum shall have precedence over the original documents and shall govern.

I. Pre-Bid Conference

A. Responses to Questions by Contractors at Pre-Bid Conference:

<u>Question/Comment (1)</u>: What is the construction budget for the project?

<u>Response (1)</u>: The construction budget for the project is \$11.8-Million.

<u>Question/Comment (2)</u>: What is the deadline for submitting questions or clarifications of the bid documents?

<u>Response (2)</u>: See Section 4.2.2 of the Instructions to Bidders and the modifications made below. All prospective bidders shall submit a written request to the Coastal Protection and Restoration Authority (CPRA) contact person (Renee McKee) 7-working days prior to the date for receipt of bids. All questions must be submitted no later than Friday, August 9, 2013.

<u>Question/Comment (3)</u>: Can work on flotation channels for the northern and southeast reaches begin prior to completing rock dike construction on the southwest reach dike.

<u>Response (3)</u>: Yes the Contractor may begin dredging of the flotation channels in other reaches prior to completing all work on the southwest reach.

<u>Question/Comment (4)</u>: Can the various reaches in the project be accepted as complete separately?

<u>Response (4)</u>: The individual reaches in the project can be accepted as complete separately. However, the 45-day lien period for release of the retainage will not begin for any portion of the project until all work on the project is deemed substantially complete and the final Notice of Acceptance is executed.

Question/Comment (5): How will the flotation channels be backfilled?

<u>Response (5)</u>: The Contractor is not allowed to backfill the flotation channels.

<u>Question/Comment (6)</u>: Will the estimated quantity of material to be excavated for the floatation channels be provided?

<u>Response (6)</u>: The table below shows the estimated quantity of material to be excavated for the construction of the flotation channels. The quantities provided are for informational purposes only.

Flotation Channel Dredging (Base Bid)								
Reach	Estimated Quantity (Cu. Yds.)							
NW Reach #1	31,403							
NE Reach	37,677							
SW Reach	66,068							
Total	135,148							
Flotation Channel Dredging (Additive Alternate #1)								
Reach	Estimated Quantity (Cu. Yds.)							
NW Reach #2	13,889							
NE Reach	-							
SW Reach	-							
SE Reach #1 & 2	59,619							
Total	73,508							

Question/Comment (7): Will the final contract amount be the contract amount awarded?

<u>Response (7)</u>: The project will be awarded at the price of the Base Bid plus any Additive Alternates accepted and awarded.

<u>Question/Comment (8)</u>: Will the contract be awarded with the Base Bid, then Additive Alternate #1, Additive Alternate #2, and then Additive Alternate #3.

<u>Response (8)</u>: The Louisiana Public Bid Law requires that the Alternates be awarded in the order that they are bid; however, the Alternates can be awarded out of sequence as long as it does not change the low bidder. The Additive Alternates have been sequenced to reflect the order of importance to the Owner.

<u>Question/Comment (9)</u>: Are the dike coordinates shown on the plans the coordinates of the dike centerline? Will that be the final alignment of the dike?

<u>Response (9)</u>: The dike coordinates shown on the plans are located at the centerline of the dike. The proposed rock dikes shall be staked by the Contractor and reviewed in the field by the Engineer prior to constructing the rock dike. Refer to TS-201.2 "Pre-Construction Survey".

<u>Question/Comment (10)</u>: How critical is the placement location of the spoil excavated for the flotation channels. Is there flexibility to place the spoil excavated for the flotation channels closer to the rock dike.

<u>Response (10)</u>: The Contractor will be required to cast the material such that the excavated material does not interfere or add pressure to the foundation of the rock dike. The location of the spoil shown in the plans is the permitted area for the placement of the spoil and therefore should be followed.

<u>Question/Comment (11)</u>: The Instructions to Bidders requires a Payment and Performance Bond and the General Provisions state that 5% will be withheld from the payments for retainage. Is there any reason why both are in the contract and can one of these be taken out of the contract.

<u>Response (11)</u>: The Payment and Performance Bond and the retainage are required and will not be removed from the contract.

<u>Question/Comment (12)</u>: What information must be submitted with the bid package (i.e. affidavit, etc.)? Can the Attestation Clause be submitted with the bid?

<u>Response (12)</u>: Reference Article 5 of the Instructions to Bidders. The only information that should be submitted with the Bid are the completed Louisiana Uniform Public Work Bid Form and the Bid Bond. All other documents shall be submitted separately after the receipt of bids.

<u>Question/Comment (13)</u>: Is there any penalty for excavating flotation channels below the Elevation -5.0'?</u>

<u>Response (13)</u>: The plans were prepared in accordance with the permits issued for the project, which have been included in Appendix D of the Bid Documents. Elevation -5.0' is the permitted elevation and the Contractor shall not dredge any lower than the permitted elevation. Any variations from the approved permits are subject to the rules and penalties set in the permitts.

<u>Question/Comment (14)</u>: Does the project have to follow the Buy American Provisions.

<u>Response (14)</u>: The project is funded with Coastal Impact Assistance Program (CIAP) funds which requires the Contractor to follow the Buy American provisions. Refer to SP-12 for additional information and requirements.

B. The Mandatory Pre-Bid Conference Attendance Record is attached at the end of this Addendum (Attachment 1A).

II. Revisions to Specifications

Page x, Instructions to Bidders, Article 4.2.2: This section shall be revised to read as follows:

4.2.2 Bidders requiring clarification or interpretation of the Bid Documents shall make a written request to the Coastal Protection and Restoration Authority contact person listed in the Advertisement for Bids, to reach him at least seven **working** days prior to the date for receipt of bids.

Page 60, TS-800.1 Temporary Warning Signs:

This section shall be <u>deleted</u> from the specifications.

Page 61, TS-800 Signage, Section 800.2.2.1. – Panel: This section shall be revised to read as follows:

Each sign shall be fabricated from minimum 3/16" thick commercial grade aluminum plate that is **four** (4) feet high and seven (7) feet wide. Each sign shall have a blue background with white lettering and display the project logos as shown in the Plans. The Owner shall provide the contractor with digital graphic files for the project logos to be used in the signs' construction.

Page 61, TS-800 Signage, Section 800.2.2.2. - Posts and Hardware: This section shall be revised to read as follows:

Posts shall be in accordance with Louisiana Standard Specifications for Roads and Bridges, latest edition, Standard Specification Section 1015.02 (a) (2). Sign posts and mountings shall be constructed as to hold the signs in proper and permanent position and to resist swaying under wind loads or displacement by vandalism. All nuts, bolts, and washers shall be hot **dip** galvanized. Nylon washers shall be installed at both ends of all bolts.

Page 61, TS-800 Signage, Section 800.2.4 – Measurement and Payment: This section shall be revised to read as follows:

Payment for this item will be included in the contract lump sum price for Bid Item No. <u>101</u>, "Mobilization and Demobilization" and shall constitute compensation for furnishing all overhead, profit, labor, materials, equipment for installation, and any other cost incidental to performing all Work as specified herein. The Owner shall pay for only one mobilization and demobilization effort. Should the Contractor demobilize prior to completing the Work, subsequent remobilization shall be performed at no cost to the Owner.

III. Additional Information

<u>Project Funding Sign Detail Sheet</u>: The attached Project Funding Sign Sheet shall be added to the Bid Documents (Attachment 1B).

ATTACHMENT 1A

Name and Signature (Sign-Out) Rand M. Melle Ronald M. Mad 5 Michael Pri nasonnier@ sellersardassociates com Ronald Madden @ Pbsgc.com Cool Mike@ SDCHOUNA. CON Fax No. and Email 6778 (337) 232.0851 Jan 985- 384-8770 Wecow e 6 69 ci 225 922-7862 985-384-Please Print Clearly 785-209-9889 7770-652 (198) 225-922-7841 Phone No. ad & Grave KA 70343 Barton Low 0, 14 70805 Sellers & Associates Lofayette, LA 70506 La 70347 148-8 Easy Street VERKO 1201-CI Airline Hung Company/Address Bros 0.14 ine Bloff Sc P.o. Box Beren cut BERRY Souther Bourg 4 Name and Signature (Sign-In) mide Enel M. Nulls Pan Pi 7 Nick

1 of 22

PROJECT: CIAP FRESHWATER BAYOU BANK STABILIZATION PROJECT (TV-11b(EB))

AGENCY: CPRA

MANDATORY PRE-BID CONFERENCE ATTENDANCE RECORD DATE: <u>AUGUST 6, 2013</u> LOCATION: <u>CPRA LAFAYETTE FIELD OFFICE, LAFAVETTE, LA</u>

ATTACHMENT 1A

Nome and Signature (Sign-Out) Car Alien Serartz	LARRY CRANE	th Callege	JERGY DEVILLE
Fox No. and Email Nome and Signature [Sign-Cut) Mrconie ro @ C.T. Bear : Can ALLEN Serants allen Surants	leramere seller sandassuciale	edg fo sensine. ne t	JEDEVILLE WERFINDER, LINGH DUNJ
Phone No. 504 - 587-8755	677-2-5-5-65	225-924-2007	985.651.3191 X.2716
Compony/Address C. F. Regn LLC Bella Chasse, LA.	SEVERS \$ \$ \$37.232.0777	SEPS. INI 11628 S.Chectan D Date Rught 78315	NHEEKS MARIMING 985 851.3191 304 6 A: ULE OR K. 2416 Copiry 444 1433
Name and Signature (Sign-In) ALLEN Sonon 72.	Long Comer	to Callasher	JERRY DEVILLE

2 of 22

MANDATORY PRE-BID CONFERENCE ATTENDANCE RECORD PROJECT: CIAP FRESHWATER BAYOU BANK STABILIZATION PROJECT (TV-11b(EB))

DATE: AUGUST 6, 2013

AGENCY: CPR

LOCATION: CPRA LAFAYETTE FIELD OFF

Please Print Clearly

LAFAYETTE, LA

ATTACHMENT 1A


Name and Signature (Sign-Out)	Leanie Dunn	when h when dress, Inc	Case Each	And the second se	Obtaten district	Dawelant	(JAMMY & JALOGO S	CHOUTHIN TR		
Fax No. and Email	318.442-8645	lonnie Clahralex. com	781. 281. 15'28	greg e chicrontature com	377 482-0635	demeil pundiff & larger		731-286-1528	Jamey & Checkentians, con		
Phone No.	318-487-9265			731-250-002		Eago-Zsh LEE			Z31-544-182		
Company/Address	P.o. Cox 50	Calendie IL 6236 Luhr Bros, Inc	P.O. Gr JEr	Dycksavar TN 38455	CPR	635 Chumane MUD.	1	CHOCTAN LAANS. CO.	1311 EAST COMAT ST 731-445-6893 DYERSBURG, 238024		
Name and Signature (Sign-In)	Lonn'e Dunn	Contra 1	Face Ford	A	DANNEY BUTT	Darregenter		JAMEY & JANOERS	lerk black		

PROJECT: <u>CIAP FRESHWATER BAYOU BANK STABILIZATION PROJECT (TV-115(EB))</u> AGENCY: <u>CPRA</u> DATE: <u>AUGUST 6, 2013</u> LOCATION: <u>CPRA LAFAVETTE FIELD OFFICE, LAFAVETTE, LA</u>

Please Print Clearly

MANDATORY PRE-BID CONFERENCE ATTENDANCE RECORD

ATTACHMENT 1A



MANDATORY PRE-BID CONFERENCE ATTENDANCE RECORD


PROJECT: <u>CIAP FRESHWATER BAYOU BANK STABILIZATION PROJECT (TV-115/EB)</u> AGENCY: <u>CPRA</u> DATE: <u>AUGUST 6, 2013</u> LOCATION: <u>CPRA LAFAVETTE FIELD OFFICE, LAFAVETTE, LA</u>

ATTACHMENT 1A

Please Print Clearly	Name and Signature (Sign-Out)		Rolque waturin				Muy Segure		1405	TERA & VILVEYS	V. CIVUNI	" HADN NUMBER	
	Fax No. and Email	Part Pristyn & Swith Consider	400.	-	MOULY. COURD ON NEOLY.	(dov		E GRAIG. RABALAIS CLA. GOV		TAVINCENT SEILERAND SEILERAND	ASSOCIATES COM		
	Phone No.	337-522-544				Sout-216-522		Mar - Oll - Siz		TTT0.737.775			5 of 22
	Company/Address	APOILO ENVILO	101 64/60	L ASAY + THA, 24	CPRA BR			CFRA/CSRS		SELLERS			
	Name and Signature (Sign-In)	RelAND MATURIN	Roldwanturin		Moury Bourscopyne	7	Murphyline	CRAIG RAPHILAIS		TODD VINCENT		1)200 A Ducart	

MANDATORY PRE-BID CONFERENCE ATTENDANCE RECORD PROJECT: <u>CLAP FRESHWATER BAYOU BANK STABILIZATION PROJECT (TV-11b(EB))</u> AGENCY: <u>CPRA</u> DATE: <u>AUGUST 6, 2013</u> LOCATION: <u>CPRA LAFAVETTE FIELD OFFICE</u>. LAFAYETTE, LA

ATTACHMENT 1A



MANDATORY PRE-BID CONFERENCE ATTENDANCE RECORD

ATTACHMENT 1B

